

SURVEYOR/WALL CONTRACTOR SHALL ADJUST THE BOTTOM OF WALL LOCATION TO ACCOUNT FOR WALL BATTER.

TRIM EXCESS FABRIC PLACED DURING CONSTRUCTION TO KEEP CAP OR TOP BLOCK CLEAN AFTER LANDSCAPING OR VEGETATION IS ESTABLISHED/COMPLETED.

CAP BLOCK OPTIONAL (EXTERIOR MASONRY ADHESIVE REQUIRED TO SET CAP)

3.8 oz. MINIMUM NEEDLEPUNCHED NON-WOVEN FILTER FABRIC.

FINISHED GRADE

EXTEND GEOGRID REINFORCEMENT TO WALL FACE

1  
16

PRIMARY GEOGRID REINFORCEMENT (SEE FINAL DESIGN FOR TYPE, LOCATION AND EMBEDMENT)

$\frac{3}{8}$ " OFFSET FOR 3.6° SETBACK

REINFORCEMENT EXTENDING BEYOND THE BACK OF BLOCK UNITS SHALL BE HORIZONTAL AND NOT BE ALLOWED TO TURN DOWN BEHIND REAR EDGE OF BLOCK.

12" MIN. #57 STONE

COVER OUTLET TO PREVENT RODENT ACCESS

TEMPORARY BACK CUT TO BE APPROVED BY ON-SITE GEOTECHNICAL ENGINEER PRIOR TO CONSTRUCTION.

FINISHED GRADE

COMPACT BACKFILL SOILS TO 95% STANDARD PROCTER MINIMUM

6" MIN

3.8 oz. MINIMUM NEEDLEPUNCHED NON-WOVEN FILTER FABRIC.

6" MIN

4" PERFORATED DRAIN PIPE TO RUN ENTIRE LENGTH OF WALL OUTLET THROUGH WALL FACE EVERY 50.0' O.C.

SEE LEVELING PAD DETAIL

GEOGRID EMBEDMENT LENGTH VARIES

# TYPICAL CROSS-SECTION

N.T.S

